

- FOR STRUCTURAL DETAILS, VAULT DIMENSIONS AND REINFORCING SEE STANDARD PRV STATION STRUCTURAL DETAILS DWG. 2357.
- 2. SEE STANDARD PRV STATION NO METER, DWG. 2354 FOR ADDITIONAL CONSTRUCTION NOTES.

## CONSTRUCTION NOTES:

- PRESSURE REDUCING VALVE, AS SPECIFIED
- В MAGNETIC FLOW METER, KROHNE M940/960, OR AS APPROVED BY THE WATER UTILITY DIVISION, COMPLETE WITH SIGNAL CONVERTER
- FLEXIBLE COUPLING WITH THRUST TIES, SEE THRUST TIE DETAIL ON DWG. 2358.
- D FLANGED TEE
- Ε BURIED BUTTERFLY VALVE (GATE VALVE FOR SIZE < 14")
- BUTTERFLY VALVE (GATE VALVE FOR SIZE < 8")
- G FLANGED SPOOL, LENGTH = 1'-0"
- ADJUSTABLE PIPE SADDLE SUPPORT, GRINNELL FIG. 264, ELCEN FIG. 50 OR EQUAL
- 1'-6" WIDE ALUMINUM LADDER W/LADDER UP SAFETY POST PER OSHA STANDARDS.
- ALUMINUM FLOOR DOOR WITH RECESSED HASP COVERED BY A HINGED LID FLUSH WITH TOP SURFACE. DOOR SIZE SHALL BE 4'x6' DOUBLE LEAF. HARDWARE AND HINGES SHALL BE TYPE 304 STAINLESS STEEL. BILCO TYPE JD OR EQUAL.
- GRAVEL PER ASTM C33, NO. 57 GRAVEL
- 6" STEEL PIPE W/GOOSENECK AND INSECT SCREEN
- 3'-0" SQ ALUMINUM FLOOR DOOR WITH RECESSED HASP COVERED BY A HINGED LID FLUSH WITH TOP SURFACE. HARDWARE AND HINGES SHALL BE TYPE 304 STAINLESS STEEL. BILCO TYPE J OR EQUAL.
- WALL PIPE WITH THRUST COLLAR, CENTER IN WALL
- R RCP CABINET FURNISHED BY THE CITY OF ALBUQUERQUE
- POWER SUPPLY AND TERMINAL CABINET S
- FLOW INDICATING TRANSMITTER
- WEATHERPROOF JUNCTION BOX FOR CONNECTION OF VAULT FLOOD LEVEL ELEMENT
- 100 AMP, 120/240 VOLT, SINGLE PHASE THREE WIRE CIRCUIT BREAKER PANEL
- RADIO AND TELEMETRY EQUIPMENT FURNISHED BY THE CITY OF ALBUQUERQUE
- WEATHERPROOF JUNCTION BOXES FOR CONNECTION TO TWO POLE MICROSWITCH FOR INTRUSION ALARM AND FOR CONNECTION TO DPDT MICROSWITCH TO ENERGIZE LIGHTS AND EXHAUST FAN WHEN ACCESS DOOR IS OPENED
- WEATHERPROOF, GFI DUPLEX RECEPTACLE 24" ABOVE FINISH FLOOR
- 2-LAMP STRIP FLUORESCENT ENCLOSED SURFACE MOUNTED LIGHT FIXTURE
- PEDESTAL TYPE 100 AMP, 120/240 VOLT, SINGLE PHASE METER AND MAIN CIRCUIT BREAKER. INSTALL ON 16"x16"x6" CONCRETE PAD PER PNM DWG #DS-19-84.0
- TELEMETRY SYSTEM MAST AND ANTENNA LOCATION TO BE DETERMINED BY CITY OF ALBUQUERQUE / WATER UTILITY DIVISION.
- 1/2" PIPE TAP WITH 1/2" BALL VALVE AND CAP
- DD INLINE EXHAUST FAN W/SWITCH AND ACCESS DOOR CONTROLS
- PRESSURE TRANSDUCER, HONEYWELL MODEL STG 644-EIG-0000-DM. PROVIDE 1/2" PIPE TAP, 1/2" BALL VALVE AND TUBING TO CONNECT TRANSDUCER TO EE PIPE BARREL
- D.I. SPOOL FLG. x P.E.
- MEGA FLANGE FLANGE ADAPTER, AS MANUFACTURED BY EBAA IRON SALES, OR APPROVED EQUAL.
- INSULATING FLANGE KIT.

REVISIONS	CITY OF ALB	UQUERQUE
	WATER	
	STANDARD PRV STATION WITH POWER/TELEMETRY	
	DWG. 2356	JANUARY 2003